



REINFORCEMENT STEEL

PIPE I.D. LONGITUDINAL BARS - LOCATION			
6 IN.	4 - NO.4 BARS	1 EACH	CORNER
8 IN.	4 - NO.4 BARS	1 EACH	CORNER
10 IN.	8 - NO.4 BARS	3 EACH	SIDE
12 IN.	8 - NO.4 BARS	3 EACH	SIDE
15 IN.	8 - NO.4 BARS	3 EACH	SIDE
18 IN.	8 - NO.4 BARS	3 EACH	SIDE
21 IN.	12 - NO.4 BARS	4 EACH	SIDE
24 IN.	12 - NO.4 BARS	4 EACH	SIDE
27 IN.	12 - NO.4 BARS	4 EACH	SIDE
30 IN.	12 - NO.4 BARS	4 EACH	SIDE
33 IN.	12 - NO.4 BARS	4 EACH	SIDE
36 IN.	16 - NO.4 BARS	5 EACH	SIDE

NOTE:

DISTRICT SHALL REVIEW THIS DETAIL FOR USE ON A CASE BY CASE BASIS. SPECIAL ENCASEMENTS MAY BE REQUIRED AT CREEK CROSSINGS AND CONDUIT CROSSINGS.

COPYRIGHT © 2016 SOUTHGATE WATER & SANITATION DISTRICTS

REVISED		 <p>Southgate WATER & SANITATION DISTRICTS</p>	SCALE
BY	DATE		NOT TO SCALE
		<p>CONCRETE ENCASEMENT DETAIL</p>	ISSUE DATE
			FEBRUARY 2016
			SHEET 1 OF 1 DRAWING NO. SS-17