



SECTION A-A

NOTES:

1. ALUMINUM BOLT DOWN COVERS ARE REQUIRED IN ALL EASEMENTS LANDSCAPED AREAS AND DRAINAGE WAYS.
2. CASTING SPECIFICATIONS: ASTM B-26 WITH A MINIMUM TENSILE STRENGTH OF 23 KSI (CLASS 25).
3. CASTINGS SHALL BE AS SPECIFIED BELOW OR EQUAL:

MANUFACTURERS	CAT. NO.
CASTINGS, INC.	MH-100-24AL
DISTRICT APPROVED EQUAL	

REVISED		 Southgate WATER & SANITATION DISTRICTS	SCALE
BY	DATE		NOT TO SCALE
		ALUMINUM 24" RING AND BOLT DOWN COVER	ISSUE DATE
			FEBRUARY 2016
			SHEET 1 OF 1 DRAWING NO. SS-07