



NOTES:

1. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS OF VAULT LAYOUT AND FITTINGS FOR APPROVAL.
2. AIR VALVES SHALL BE SIZED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
3. FOR APPROVED MANUFACTURER'S AND MODEL NUMBERS OF FITTINGS, REFER TO SPECIFICATIONS.
4. ISOLATION VALVES SHALL BE BALL STYLE WITH HAND LEVER AND SHALL BE THREADED OR FLANGED, AS APPROVED.
5. STRUCTURE SHALL BE H20 LOAD RATED.

REVISED	
BY	DATE



COMBINATION AIR VALVE ASSEMBLY

SCALE	NOT TO SCALE
ISSUE DATE	FEBRUARY 2016
SHEET	DRAWING NO.
1 OF 1	W-10